



中国国家强制性产品认证证书

证书编号：2017010307014257

委托人名称、地址

上海天逸电器有限公司

上海市松江区车墩镇北闵路 101 号第二、三幢

生产者（制造商）名称、地址

上海天逸电器有限公司

上海市松江区车墩镇北闵路 101 号第二、三幢

生产企业名称、地址

上海天逸电器有限公司

上海市松江区车墩镇北闵路 101 号第二、三幢

产品名称和系列、规格、型号

剩余电流动作断路器

TYB2PLEN; Ue: AC 230V; In: 6A、10A、16A、20A、25A、32A、40A; C、D 型
特性; I Δ n: 30mA、; AC、A 型; 电子式; I Δ m: 2000A; Icn=Ics=6kA;; 级数: 1P+N
(带一个保护极, N 极可开闭)

产品标准和技术要求

GB/T16917. 1-2014;GB/T16917. 22-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2017 年 10 月 23 日 有效期至: 2022 年 10 月 23 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2017010307014257

NAME AND ADDRESS OF THE APPLICANT

Shanghai TAYEE Electric.Co.,Ltd.
No.101 Beimin Road,Chedun Town,Songjiang District,Shanghai,P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Shanghai TAYEE Electric.Co.,Ltd.
No.101 Beimin Road,Chedun Town,Songjiang District,Shanghai,P.R.China

NAME AND ADDRESS OF THE FACTORY

Shanghai TAYEE Electric.Co.,Ltd.
No.101 Beimin Rd,Chedun Town Songjiang District,Shanghai

PRODUCT NAME, MODEL AND SPECIFICATION

Residual Current Operated Circuit-breaker

TYB2PLEN; Ue: AC 230V; In: 6A、10A、16A、20A、25A、32A、40A; C、DC type characteristics; I Δ n: 30mA、; Type AC、A; Electronic; I Δ m: 2000A; Icn=Ics=6kA; Poles: 1P+N (one protected pole with a switched neutral pole)

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T16917.1-2014;GB/T16917.22-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Oct.23,2017

Valid until: Oct.23,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE